

2021 Annual Drinking Water Quality Report

Town of Goshen

**INTRODUCTION**

This Annual Drinking Water Quality Report for calendar year is designed to provide you with valuable information about your drinking water quality. The Town of Goshen is committed to providing you with a safe and dependable supply of drinking water, and we want you to understand the efforts we make to protect your water supply. The quality of your drinking water meets all state and federal requirements administered by the Virginia Department of Health (VDH), Office of Drinking Water.

If you have questions about this report, want additional information about any aspect of your drinking water, or want to know how to participate in decisions that may affect the quality of your drinking water, please contact:

Mr. Thomas McGraw at (540) 997-5545

**GENERAL INFORMATION**

The sources of drinking water (both tap water and bottled water) includes, rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity. Contaminants that may be present in source water include: (1) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife. (2) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming. (3) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses. (4) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems. (5) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Water from surface sources is treated to make it drinkable while groundwater may or may not have any treatment. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

**SOURCE AND TREATMENT OF YOUR DRINKING WATER**

Your drinking water is groundwater obtained from one spring. The spring outcrops in a low isolated area northwest of the town along Mill Creek but segregated from it by the railroad tracks. This system also consists of a booster pumping station, a standpipe, and a distribution system.

Chlorination treatment is provided for the spring.

The Virginia Department of Health has established a design capacity for the Town of Goshen waterworks to be 228,000 gpd or 570 residential connections.

**SOURCE WATER ASSESSMENT**

A source water assessment has been completed by VDH. The assessment determined that our sources may be susceptible to contamination because they are located in an area that promotes migration of contaminants from land use activities of concern. More specific information may be obtained by contacting the water system representative listed above.

**QUALITY OF YOUR DRINKING WATER**

Your drinking water is routinely monitored according to Federal and State Regulations for a variety of contaminants. The tables that follow show the results of our monitoring for the period of January 1<sup>st</sup> through December 31<sup>st</sup>, 2021.

**WATER QUALITY RESULTS**

<b>Inorganic Contaminants</b>						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Nitrate ppm	10	10	0.06	No	April 2021	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Barium ppm	2	2	0.042	No	April 2019	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
Sodium mg/l	-	-	0.969	No	April 2020	Erosion of natural deposits; de-icing salt runoff; water softeners
<b>Radiological Contaminants</b>						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Combined Radium pCi/L	0	5	ND	No	January 2020	Erosion of natural deposits
Alpha emitters pCi/L	0	15	1	No	January 2020	Erosion of natural deposits
Gross Beta pCi/L	0	50	ND	No	January 2020	Decay of natural and man-made deposits
<b>Lead &amp; Copper</b>						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found / Range	Exceedance	Date of Sample	Typical Source of Contamination
Copper ppm	1.3	AL=1.3	0.117 (90 <sup>th</sup> percentile) None of the five samples collected exceeded copper AL.	No	July 2019	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
Lead ppb	0	AL=15	2.88 (90 <sup>th</sup> percentile) None of the five samples collected exceeded lead AL.	No	July 2019	Corrosion of household plumbing systems; Erosion of natural deposits
<b>Disinfection By-products</b>						
Contaminant/Unit of Measurement	MCLG	MCL	Level Found	Violation	Date of Sample	Typical Source of Contamination
TTHM's (Total Trihalomethanes) ppb	NA	80	17	No	September 2021	By-product of drinking water chlorination
Haloacetic acids (HAAs) ppb	NA	60	2.1	No	September 2021	By-product of drinking water chlorination
<b>Disinfectant Residual</b>						
Disinfectant/Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Chlorine mg/L	4	4	0.32 to 1.04	No	Monthly	By-product of drinking water chlorination

The results in the table are from testing done in 2019, 2020 and 2021. The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.

We constantly monitor for various contaminants in the water supply to meet all regulatory requirements. The table lists only those contaminants that had some level of detection. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

Maximum Contaminant Levels (MCL's) are set at very stringent levels by the U.S. Environmental Protection Agency. In developing the standards, EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCL's at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-a-million chance of having the described health effect for other contaminants.

**VIOLATION INFORMATION**

We did not have any violations in 2021.